



Product Safety Recall

Chubb Fire & Security Pty Ltd has announced a voluntary recall of certain:

Chubb and Flameguard 1.5kg, 2.3kg, 2.5kg and 4.5kg dry powder fire extinguishers.

The recall affects fire extinguishers purchased between 16 February and 8 July 2010 with the following serial numbers:

Fire Extinguisher	Size (kg)	From Serial No.	To Serial No.
Chubb, Flameguard	1.5	SA358508 SA617007	SA358699 SA640579
Chubb, Flameguard	2.3	SA335255 SA617193	SA357445 SA644756
Chubb, Flameguard	2.5	SA335051 SA620547	SA358273 SA640681
Chubb, Flameguard	4.5	SA336827 SA617637	SA357661 SA644909

Chubb believes through in-house testing that a proportion of these fire extinguishers may not meet Australian Standards in relation to filling capacity requirements.

As a result, the affected fire extinguishers may not release a sufficient steady stream of powder.

Chubb advises customers to return the product to the company of purchase for a new replacement or speak to your local Chubb representative.

For more information visit www.chubb.com.au or call 1300 369 636 Monday to Friday between 8am and 5pm.

See www.recalls.gov.au for Australian Product Recall Information



Serial No.

