

ELECTRICAL SAFETY RECALL

Clipsal 230DRAS1MI and 230DRAS2MI Meter Boxes



IDENTIFICATION:

Affected product was sold to and available for purchase from electrical wholesalers in South Australia between January 2015 and July 2015 (inclusive) and can be identified by:

- a) 230DRAS1MI with serial numbers between S12014480001 and S12015252308
- b) 230DRAS2MI with serial numbers between S22014480001 and S22015100570

HAZARD:

A screw on the side of the meter isolator may be electrically live. There is a risk of electric shock if contact is made with this screw.

ACTION REQUIRED:

1. Check your stock for affected product.
2. Review sales and installations that may have used affected product.
3. Where affected product has been identified, please return immediately to place of purchase. If product is already installed and cannot be returned then contact us for further details about rectification.

For further information

Please direct all calls and any queries concerning this recall to



Website: clipsal.com/230DRASrecall

Phone: 1300 733 907

See www.recalls.gov.au for Australian product recall information