

Product Safety Recall

Kirby Packaged Drop-in Refrigeration Units



Model affected: KPC800-6, KPC1000-6, KPC1400-6, KPC1700-6,
KSC2000-6, KSC2700-6, KSC3500-6

Serial number range: 1108xxxxxx to 1202xxxxxx

When sold: Sep 2011 to Apr 2012

What is the fault?

The units are potentially charged with counterfeit refrigerant that is flammable when exposed to atmosphere and causes premature system failure.

What are the hazards?

If the counterfeit refrigerant is exposed to atmosphere there is a risk of fire through spontaneous ignition and formation of hazardous fumes.

What to do

Check the model and serial number located on top of the unit. If your model is listed above and the serial number range please contact Heatcraft on 02 9774 7222 or emailing dropinrecall@heatcraft.com.au to arrange a replacement unit. **Under no circumstances** are the units to have the refrigerant replaced by a service technician in-situ. The unit must be returned to Heatcraft intact with its refrigerant charge.



Heatcraft Australia Pty Ltd
A.B.N. 67 000 056 717
286 Horsley Rd, Milperra NSW 2214

See www.recalls.gov.au for
Australian Product Recall Information