

## Product Safety Recall



**Iplex K1 25mm K1 x 20mm BSP Male Adaptor Part N° FK1522520**

Sold at Tradelink and Swan Plumbing Supply outlets in New South Wales and Victoria between 6<sup>th</sup> March and 3<sup>th</sup> August 2012.

**Explanation** In some instances the fitting has cracked when crimped to 25mm K1 multilayer gas pipe.

**Hazard** If the crack is undetected at the time of installation or during subsequent pressure testing, gas leakage may occur.

**What to do** Consumers and gas fitters who have purchased the fitting from the nominated outlets between 6<sup>th</sup> March and 3<sup>th</sup> August 2012 should immediately contact Iplex Pipelines to arrange a replacement of the fitting at no cost to the consumer.

**Contact Details** Contact Iplex Pipelines, Grant Murray or Kym Overs telephone 13 18 40 or email [gas@iplexpipelines.com.au](mailto:gas@iplexpipelines.com.au)

**See [www.recalls.gov.au](http://www.recalls.gov.au) for  
Australian Product Recall Information**