


# ELECTRICAL SAFETY RECALL

## Transco Electrical Residual Current Device combined with Miniature Over Current Circuit Breaker

3kA, single pole plus neutral, 240 Volt, 30 mA, 18mm din-mounted AC type 10A, 16A, 20A, 25A, 32A



Sold between January 2019 and May 2019 by Belmore Electrical (NSW), JNJ Electrical (t/a ELS Electrical & Lighting Solutions) (NSW), A.J. Electrical (VIC), and Go Electrical (Tuggerah NSW)

### Identification:

Brand Transco  
Model RCDMCB10S/RCDMCB16S/RCDMCB20S  
Batch number 201811 marked on product

**Defect:** The product does not comply with the relevant mandatory electrical safety standard. The device may not provide circuit protection.

**Hazard:** Risk of electric shock, which can cause serious injury or death.

**Action Required:** Consumers should stop using the product immediately and contact Magical Electrical Pty Ltd to arrange to return the product to the place of purchase for a full refund or replacement.

**Contact Details:** For further information, please contact Magical Electrical Pty Ltd by phone on 02 9057 9047 (Monday to Friday, 9.30am - 4.30pm AEST) or email [maksim.feng@transco.net.au](mailto:maksim.feng@transco.net.au)

See [www.productsafety.gov.au](http://www.productsafety.gov.au) for Australian product recall information