



Product Safety Recall



Do you own this product?

Corinthian BAL 29 doors

BAL 29 Rural Collection range: Rural 03, Rural 04, Rural 101, Rural 101 SL, Rural 104, Rural 106, Rural 7 & Rural 21

Dates sold: 1 July 2020 – 31 August 2024



Why the product is recalled: Affected doors contain glass inserts that are not BAL 29 compliant and may not withstand BAL 29 bushfire conditions.

Hazard: There is risk of serious injuries including burns, death, and property damage if the glass inserts fail during bushfire conditions.



1. If you have an affected door, Corinthian Doors will send a letter to the door installation address and contact you by phone.
2. Corinthian Doors will arrange to replace the glass insert with one that is BAL 29 compliant free of charge.



If you have not been contacted by Corinthian and think you have an affected door, you can call Corinthian Doors customer service on 1300 899 153



Purchased from: Corinthian Doors, various builders and hardware stores



Set yourself a reminder to check at home

- Take a photo of this notice
- Set a reminder on your phone

PRA 2024/20291

See [productsafety.gov.au](https://www.productsafety.gov.au) for
Australian product recall information