

ELECTRICAL SAFETY RECALL

Electrical components sold within 'SmartSpace' Kit Homes



IDENTIFICATION:

Cable

SDI CABLE 1.5mm² V90 450/750V TO AS/NZS 5000.2 YAFEI

SRF CABLE 3 x 2.5mm² 450/750V V90 TO AS/NZS 5000.2 YAFEI

SRF CABLE 3 x 1.5mm² 450/750V V90 TO AS/NZS 5000.2 YAFEI

Circuit Breaker and Residual Current Device (RCD)

Marked JVM21-63 C16 240/415V~

Marked RCBO JVL5 C16 30mA 240V~

The products were sold by Bunnings in Australia as part of the 'SmartSpace' Kit Homes prior to July 2015. This recall does not affect SmartSpace Kit Homes that were purchased after July 2015. No other product is affected.

The various electrical components supplied with the 'SmartSpace' Kit Homes were not sold separately.

HAZARD:

The cables have failed some of the required ageing tests of AS/NZS 5000.2. The insulation could become prematurely brittle with age. If the insulation becomes brittle and the cables are disturbed, the insulation could break and expose live conductors, resulting in possible electric shock or fires. The circuit breaker and RCD do not pose a safety risk, however these components are not approved for sale in Australia.

ACTION REQUIRED:

Home occupiers who are concerned that these components have been used in their homes should contact the SmartSpace support team on the details below. The SmartSpace support team will arrange for a licensed electrician to inspect their home and replace the affected electrical components.

For further information

Ph. 1300 985 110 or email info@smartspacehomes.com.au

See www.productsafety.gov.au for Australian product recall information