

ELECTRICAL SAFETY RECALL

Battery Energy Storage Device UltraFlex



IDENTIFICATION: UltraFlex 48-4, 48-3 and 48-2 sold through Smart Storage Pty Ltd t/as Ecoult and electrical integrators between June 2014 and November 2019.

DEFECT: The UltraFlex was not designed to independently protect itself or the user against excessive voltage, overheating, or excessive gassing when combined with particular other equipment in a system.

HAZARD: Risk of fire and electrocution, which may lead to serious injury or death.

ACTION REQUIRED:

Consumers should immediately contact Ecoult to arrange for the decommissioning and removal of the UltraFlex units by a licensed electrician. Ecoult will provide a refund and remove the UltraFlex units.

CONTACT DETAILS:

For further information, contact Ecoult by phone on 02 9241 3001, via email at info@ecoult.com or going to <https://www.ecoult.com/contact>

See www.productsafety.gov.au for Australian product recall information