

ELECTRICAL SAFETY RECALL

Single module Compact RCBO Noark model no. Ex9NLE-N

Identification:

Products affected include:

- 90552 - 1 module RCBO 10A 30mA
- 90553 - 1 module RCBO 16A 30mA
- 90554 - 1 module RCBO 20A 30mA
- 90555 - 1 module RCBO 25A 30mA
- 90556 - 1 module RCBO 32A 30mA
- 90703 - 1 module RCBO 40A 30mA

These products have been sold in Victoria, South Australia and Western Australia between March 2016 and October 2019.



Defect: The products do not comply with the relevant mandatory electrical safety standard.

When the unit malfunctions, it does not switch off the circuit as required.

Hazard: Risk of electric shock, which can cause serious injury or death.

Action required: Consumers should immediately stop using the products and contact DKSH to arrange return of their product and for replacement product.

Contact Details: For further information, please contact DKSH Australia Pty Ltd by phone on 1800 006 137 (Monday to Friday, 9am - 5pm AEST), email recall.au@dksh.com or visit <https://dksh.com/noark-rcbo-recall>

See www.productsafety.gov.au for Australia Product Recalls Information