

ELECTRICAL SAFETY RECALL

Single module Compact RCBO Noark model no. Ex9NLE-N

Identification:

Products affected include:

- 90552 - 1 module RCBO 10A 30mA
- 90553 - 1 module RCBO 16A 30mA
- 90554 - 1 module RCBO 20A 30mA
- 90555 - 1 module RCBO 25A 30mA
- 90556 - 1 module RCBO 32A 30mA
- 90703 - 1 module RCBO 40A 30mA

Defect: The product does not comply with the relevant mandatory electrical safety standard.

When the unit malfunctions, it does not switch off the circuit as required.

Hazard: Risk of electric shock, which can cause serious injury or death.

Action Required: Consumers should immediately stop using the product and contact Simple Electric to arrange return of their product and for a replacement product.

Visit www.simpleelectric.com.au for more information on the recall or to register the location of recalled RCBOs.

Contact Details: For further information, please contact Simple Electric by email at recall@simpleelectric.com.au or by phone on 03 9190 8966.



See www.productsafety.gov.au for Australia Product Recalls Information