

Product Safety Recall

KIDDE FIRE EXTINGUISHER 2-3LB MARINER 5



**KIDDE BRANDED FIRE EXTINGUISHER SOLD TO RIVIERA AUSTRALIA BETWEEN
10 JANUARY 2012 – 17 OCTOBER 2014**

DEFECT:

The fire extinguishers can become clogged or require excessive force to discharge and can fail to activate during a fire emergency. In addition, the nozzle can detach with enough force to pose an impact hazard.

HAZARD:

If the fire extinguisher does not function properly, it can increase the risk of injury and/or property damage in the event of a fire.

WHAT TO DO IF YOU HAVE THIS PRODUCT:

Contact Chubb immediately to request a free replacement fire extinguisher and for instructions on returning the recalled unit.

DO NOT use the recalled unit in a fire emergency.

HOW TO CONTACT CHUBB:

- Contact: Rotha Tan, Quality Manager
- Phone: 0448 277 553
- Email: rotha.tan@chubb.com.au

See www.recalls.gov.au for
Australian Product Recall Information