

Electrical Safety Recall

Sein Company Pty Ltd is recalling SV power supply model AP-5A DC12 with 4 outputs



DEFECT:

The power supply construction does not comply with the electrical safety standard. A fault in the power supply can cause the output to have a hazardous voltage.

IDENTIFICATION:

The DIN mounted power supply is designed for use with CCTV installations and has been sold by SecuVision CCTV, Mt Waverley from Feb 2017 to June 2018. The product was sold in Victoria and South Australia only.

HAZARD:

Risk of electric shock

ACTION REQUIRED:

- Do not attempt to remove the power supply from the installation. Contact the installer who can arrange to safely replace the power supply.
- For the installer, ENSURE THE POWER IS ISOLATED when replacing the power supply unit.
- The supplier will be contacting all CCTV installers who have purchased this power supply.

CONTACT DETAILS:

For further information, please contact SecuVision CCTV on 03 8568 5168 or email warranty@secuvisioncctv.com.au or sales@secuvisioncctv.com.au

See www.productsafety.gov.au or Australian Product Recall Information