


ELECTRICAL SAFETY RECALL

Residual Current Device (RCD)

Brand name Dielle, Model YK78, Approval mark N.21905



DEFECT:

RCD may fail product standard test requirements. Approval mark N.21905 is not valid.

IDENTIFICATION:

RCD product marked with 'Dielle', 'YK78' and 'N.21905' - see above photos.
6A, 10A, 16A, 20A, 25A and 32A.
Product sold from 2006 onwards.

HAZARD:

Potential risk to persons or property of electric shock or fire.

ACTION REQUIRED:

If you have or suspect you have the recalled RCD product installed within your premises, you should engage a licensed electrical contractor to examine the RCD/s and replace any affected product with an alternative RCD that has a valid Australian approval mark.

The distributor of the recalled RCD product, Dielle Electrical Distributors Pty Ltd, is no longer trading.

See www.productsafety.gov.au for Australian product recall information